SIEMENS 7817



Actuator SQM40.../SQM41...

# Actuators for air and gas dampers

**SQM40... SQM41...** 

- Electromotoric actuator up to 18 Nm torque
- Clockwise and counterclockwise variants
- Running times from 5 up to 65 seconds
- · Different shaft ends available
- Electronic version with analog control input
- Internal position indication
- Drive shaft can be disengaged
- Variants with UL and CSA approval, as well as GL marine approval

The SQM40.../SQM41... and this Data Sheet are intended for use by OEMs which integrate the actuators in their products!

#### Use

The SQM40.../SQM41... actuators are suited for driving oil pressure controller, butterfly valves, dampers or for use on other applications that require rotary motion. Areas of application are oil and gas burners of medium to higher capacity as well as thermal process plants.

The actuators are used primarily for load-dependent control of the flow of gas, oil and combustion air:

- In connection with 3-position or modulating controllers (e.g. 4...20 mA), and/or ...
- ... directly by burner controls

Product type	Type of documentation	Documentation number
SQM45 / SQM48	Data Sheet	N7814
SQM10 / SQM20	Data Sheet	N7812
ASZ	Data Sheet	N7921
ASZ22.3x	Mounting Instruction	74 319 0921 0 (M7921)

#### Warning notes



To avoid injury to persons, damage to property or the environment, the following warning notes must be observed!

#### Only qualified personnel may open, interfere with or modify the actuators!

- Read the documentation on the actuators carefully and fully. If not observed, dangerous situations might occur
- The user must ensure that the actuators meet the requirements of the relevant application standards
- Safety-related applications are only available with Siemens burner controls!
- All product-related activities (mounting, settings and maintenance) must be performed by qualified and authorized personnel



#### Caution!

- Risk of electric shock hazard to disconnect the actuator from power, it may be necessary to open more than one switch. Before performing maintenance work, the actuator must be disconnected from power
- The electrical connection between the conduit fittings is not made automatically.
   It must be established on installation site
- The connecting plate is made of plastic and does not provide earthing of the conduit fittings. Earthing must be ensured by adequate washers and wire links
- All cam switch settings must satisfy the requirements of the relevant application standards
- To provide protection against electric shock hazard, the connecting terminals must have adequate touch protection. Make certain that non-insulated connections or wires cannot be touched
- Each time work has been carried out (mounting, installation, service work, etc.),
   check to ensure that wiring is in an orderly state
- Fall or shock can adversely affect the safety functions. Such actuators must not be put into operation even if they do not exhibit any damage
- Static charges must be avoided since they can damage the actuator's electronic components when touched.

Recommendation: Use ESD equipment

#### Notes on use in North America

- Use of flexible conduit including adequate accessories is mandatory
- Use of copper wiring is mandatory
- All circuits of class 2 must use cables type CL3, CL3R, CL3P or comparable types, OR

All circuits are wired according to class 1 (electrical light or power circuits)


Building Technologies Division CC1N

- Ensure that the relevant national safety regulations and notes on standards are complied with
- In geographical areas where DIN regulations apply, the mounting and installation requirements of VDE must be satisfied, especially DIN/VDE 0100, 0550 and DIN/VDE 0722
- Make certain that the actuator is not exposed to direct solar radiation
- Required tightening torques for the fixing screws of the
  - housing cover: 3.5 Nmconnecting cover: 2 Nm



#### Note!

Ensure correct direction of rotation!



#### Installation notes

- Ensure that the electrical wiring is in compliance with national and local safety regulation
- Make certain that strain relief of the connected cables conforms to the relevant standards (e.g. as per DIN EN 60730 and DIN EN 60335)
- Ensure that spliced wires cannot get into contact with neighboring terminals. Use adequate ferrules
- Unused terminals of the SQM40.../SQM41... must be covered by dummy plugs
- When making the wiring, the AC 120 V or AC 230 V section must be separated from other voltage sections, thus ensuring protection against electric shock hazard
- The connection between the actuator drive shaft and the relevant controlling element must be form-fitted
- Only plastic versions of cable glands may be used


- The actuators must always be powered via a prefuse of max. 6.3 AT (as per DIN EN 6012- 2/5)
- For the protective earth connection, the housing of all variants has a marked PE connecting terminal. A tightening torque of 1.2 Nm must be observed for fitting the screw
- The supplied RAST3.5 connectors or RAST5 connectors must be used with screw terminals for electrical connections. A tightening torque of 0.25 Nm must be observed for fitting the screw



#### Note!

The connection of fuel valves is only permitted on fused output terminals, see chapter *Connection diagrams*. For this purpose, specific unit variants are available fitted with a unit-internal, non-replaceable fuse. The unit-internal fuse is used to protect each switching contact from welding in the event of external short-circuit. In addition, please note that the maximum current load for the fused output terminals is reduced, see chapter *Connection diagrams*.

#### Marking of the SQM40... / SQM41... connection areas:





#### Note

SELV or PELV depends on the safety class of the connected components. In the case of PELV, the relevant component is connected to protective earth.

Building Technologies Division CC1N7817en 11.02.2016

The mechanical setting facility for the cams is physically separated from the connection terminals. When the actuator is disconnected from power, the switches can be adjusted via a scale. The cams can be changed via adjusting screws. The scale indicates the angles of the switching points.

#### Standards and certificates



#### Applied directives:

Low-voltage directive

2006/95/EC

Electromagnetic compatibility EMC (immunity) \*)

2004/108/EC

\*) The compliance with EMC emissions requirements must be checked after the actuator has been installed in the work equipment.

Compliance with the regulations of the applied directives is verified by the adherence to the following standards / regulations:

Automatic electrical controls for household and similar use Part 2-14:

DIN EN 60730-2-14

Special requirements on electric actuators

DIN EN 60730-1 Automatic electrical controls for household and similar use Part 1: General requirements



EAC Conformity mark (Eurasian Conformity mark)



ISO 9001:2008 ISO 14001:2004 OHSAS 18001:2007





For types marked with **R** Example: SQM40.264R10

For use in US/Canada where the power supply lines require a connection facility for flexible conduit, the actuator's product no. includes type suffix «R» (see following example). These products are **UL**-listed.



For types marked with 36 or 38

Examples: SQM4x.36xA2x, SQM4x.38xA2x

For marine applications, environmental category A.

#### Lifetime

The actuator has a designed lifetime\* of 250,000 start cycles

(close ⇒ open ⇒ close) under load with the rated torque in the entire rotation angle range, which under normal operating conditions in heating mode corresponds to approx.

10 years of usage (starting from the date of manufacture on the device type plate). This lifetime is based on the endurance tests specified in standard EN 298.

A summary of the conditions has been published by the European Control Manufacturers Association (Afecor - www.afecor.org).

The designed lifetime is based on use of the actuator according to the manufacturer's Data Sheet. After reaching the designed lifetime in terms of the number of startup cycles, or the respective time of usage time, the actuator is to be replaced by authorized personnel.

\* The designed lifetime is not the warranty time specified in the Terms of Delivery.

#### Disposal notes



The unit contains electrical and electronic components and must not be disposed of together with domestic waste.

Local and currently valid legislation must be observed.

5/29

**Building Technologies Division** 

#### Mechanical design

Housing


- Lower housing part made of die-cast aluminum
- Housing cover made of impact-proof and heat-resistant plastic

Drive motor

Synchronous motor

Coupling

- Shaft can be manually disengaged from the motor by operating the coupling (coupling pin (K1))
- Automatic reengagement
   Disengagement of drive shaft / motor by pressing coupling pin «K1»



Earthing connection

Earth terminal (PE) with screw fitting

Cam shaft drive

· Non-reactive gear

Adjustment of switching points

- With adjustable cams
- Scales beside the cams indicate the angle of the switching point

Position indicator

- Internally
  - Scale 0...135° at the end of the cam assembly
  - Scale range to direction of rotation with arrow marking for SQM41 or with marking

in slot die for SQM40

Electrical connections

- RAST3.5 screw terminals are factory supplied, depending on the PCB variant
- RAST5 screw terminals are factory supplied, depending on the PCB variant
- Optional: Insulation displacement connectors
- Cable entry by means of 2 openings in the connector cover supplied.
   The cable glands are not included in the scope of delivery
- Large openings in the housing allow easy cable installation

Gear train

Maintenance-free gearwheels and bearings.

Drive shaft

- Different shaft versions available, shafts are supplied assembled
- Drive shaft is not replaceable

Actuator fixing

Mounting holes on the lower side of the housing (shaft side), such as actuators SQM45... / SQM48... using M5 screws, or alternatively as actuators SQM10... / SQM20... front mounting using M5 self-tapping screws (see chapter *Dimensions*).

#### Type summary (other types on request)

		Direct rota		or 90°			РСВ					_	ional sion	Oper volt	_	Pote me	
Article no.	Туре	Counter- clockwise	Clockwise	Torque ¹) / running time ¹) for 90°	Electronic version Diagram no.	Switch version Diagram no.	3-position	2-position	No. of switches	No. of relay	Shaft no.	EU	US / Canada	AC120V	AC230V	Double 90°	Double 135°
BPZ:SQM40.025A21	SQM40.025A21	•		2,5 Nm / 5 s	2				4		5	•			•	•	
BPZ:SQM40.065A23	SQM40.065A23	•		2,5 Nm / 5 s		6	•		6		5	•			•		•
BPZ:SQM40.115R11	SQM40.115R11	•		5 Nm / 15 s	1				3		5		•	•		•	
BPZ:SQM40.115R13	SQM40.115R13	•		5 Nm / 15 s	1				3		5		•	•			•
BPZ:SQM40.141A21	SQM40.141A21	•		5 Nm / 15 s	4				3		1	•			•	•	
BPZ:SQM40.144R11	SQM40.144R11	•		5 Nm / 15 s	4				3		4		•	•		•	
BPZ:SQM40.145A21	SQM40.145A21	•		5 Nm / 15 s	4				3		5	•			•	•	
BPZ:SQM40.145R11	SQM40.145R11	•		5 Nm / 15 s	4				3		5		•	•		•	
BPZ:SQM40.155R11	SQM40.155R11	•		5 Nm / 15 s	5				4		5		•	•		•	
BPZ:SQM40.155R13	SQM40.155R13	•		5 Nm / 15 s	5				4		5		•	•			•
BPZ:SQM40.161A20	SQM40.161A20	•		5 Nm / 15 s		6	•		6		1	•			•		
BPZ:SQM40.165A20	SQM40.165A20	•		5 Nm / 15 s		6	•		6		5	•			•		
BPZ:SQM40.165A21	SQM40.165A21	•		5 Nm / 15 s		6	•		6		5	•			•	•	
BPZ:SQM40.165R11	SQM40.165R11	•		5 Nm / 15 s		6	•		6		5		•	•		•	
BPZ:SQM40.171A20	SQM40.171A20	•		5 Nm / 15 s		7		•	5	1	1	•			•		
BPZ:SQM40.175A21	SQM40.175A21	•		5 Nm / 15 s		7		•	5	1	5	•			•	•	

**Building Technologies Division** 11.02.2016

**Type summary** (other types on request) (cont'd)

		Direct rota		or 90°			РСВ					Regi vers		-	ating age	Pote me	
Article no.	Туре	Counter- clockwise	Clockwise	Torque ¹) / running time ¹) for 90°	Electronic version Diagram no.	Switch version Diagram no.	3-position	2-position	No. of switches	No. of relay	Shaft no.	EU	US / Canada	AC120V	AC230V	Double 90°	Double 135°
BPZ:SQM40.185R11	SQM40.185R11	•		5 Nm / 15 s		8	•		6		5		•	•		•	
BPZ:SQM40.215R11	SQM40.215R11	•		10 Nm / 30 s	1				3		5		•	•		•	
BPZ:SQM40.215R13	SQM40.215R13	•		10 Nm / 30 s	1				3		5		•	•			•
BPZ:SQM40.235A20	SQM40.235A20	•		10 Nm / 30 s		3		•	4	3	5	•			•		
BPZ:SQM40.241A21	SQM40.241A21	•		10 Nm / 30 s	4				3		1	•			•	•	
BPZ:SQM40.241R11	SQM40.241R11	•		10 Nm / 30 s	4				3		1		•	•		•	
BPZ:SQM40.244A21	SQM40.244A21	•		10 Nm / 30 s	4				3		4	•			•	•	
BPZ:SQM40.244R11	SQM40.244R11	•		10 Nm / 30 s	4				3		4		•	•		•	
BPZ:SQM40.245A11	SQM40.245A11	•		10 Nm / 30 s	4				3		5	•		•		•	
BPZ:SQM40.245A21	SQM40.245A21	•		10 Nm / 30 s	4				3		5	•			•	•	
BPZ:SQM40.245R11	SQM40.245R11	•		10 Nm / 30 s	4				3		5		•	•		•	
BPZ:SQM40.247A21	SQM40.247A21	•		10 Nm / 30 s	4				3		7	•			•	•	
BPZ:SQM40.255A21	SQM40.255A21	•		10 Nm / 30 s	5				4		5	•			•	•	
BPZ:SQM40.255R11	SQM40.255R11	•		10 Nm / 30 s	5				4		5		•	•		•	
BPZ:SQM40.255R13	SQM40.255R13	•		10 Nm / 30 s	5				4		5		•	•			•
BPZ:SQM40.261A11	SQM40.261A11	•		10 Nm / 30 s		6	•		6		1	•		•		•	
BPZ:SQM40.261A20	SQM40.261A20	•		10 Nm / 30 s		6	•		6		1	•			•		
BPZ:SQM40.261A21	SQM40.261A21	•		10 Nm / 30 s		6	•		6		1	•			•	•	
BPZ:SQM40.261R11	SQM40.261R11	•		10 Nm / 30 s		6	•		6		1		•	•		•	

Building Technologies Division CC1N7817en

Type summary (other types on request) (cont'd)

	Direction of containing position pcb								_	ional sion	-	ating tage	Pote				
Article no.	Туре	Counter- clockwise	Clockwise	Torque ¹) / running time ¹) for 90°	Electronic version Diagram no.	Switch version Diagram no.	3-position	2-position	No. of switches	No. of relay	Shaft no.	EU	US / Canada	AC120V	AC230V	Double 90°	Double 135°
BPZ:SQM40.265A11	SQM40.265A11	•		10 Nm / 30 s		6	•		6		5	•		•		•	
BPZ:SQM40.265A20	SQM40.265A20	•		10 Nm / 30 s		6	•		6		5	•			•		
BPZ:SQM40.265A21	SQM40.265A21	•		10 Nm / 30 s		6	•		6		5	•			•	•	
BPZ:SQM40.265R11	SQM40.265R11	•		10 Nm / 30 s		6	•		6		5		•	•		•	
BPZ:SQM40.267A20	SQM40.267A20	•		10 Nm / 30 s		6	•		6		7	•			•		
BPZ:SQM40.271A20	SQM40.271A20	•		10 Nm / 30 s		7		•	5	1	1	•			•		
BPZ:SQM40.274R10	SQM40.274R10	•		10 Nm / 30 s		7		•	5	1	4		•	•			
BPZ:SQM40.275A20	SQM40.275A20	•		10 Nm / 30 s		7		•	5	1	5	•			•		
BPZ:SQM40.275A21	SQM40.275A21	•		10 Nm / 30 s		7		•	5	1	5	•			•	•	
BPZ:SQM40.275R10	SQM40.275R10	•		10 Nm / 30 s		7		•	5	1	5		•	•			
BPZ:SQM40.281A20	SQM40.281A20	•		10 Nm / 30 s		8	•		6		1	•			•		
BPZ:SQM40.285R11	SQM40.285R11	•		10 Nm / 30 s		8	•		6		5		•	•		•	
BPZ:SQM40.317A23	SQM40.317A23	•		18 Nm / 65 s	1				3		7	•			•		•
BPZ:SQM40.317R11	SQM40.317R11	•		18 Nm / 65 s	1				3		7		•	•		•	
BPZ:SQM40.317R13	SQM40.317R13	•		18 Nm / 65 s	1				3		7		•	•			•
BPZ:SQM40.357R11	SQM40.357R11	•		18 Nm / 65 s	5				4		7		•	•		•	
BPZ:SQM40.357R13	SQM40.357R13	•		18 Nm / 65 s	5				4		7		•	•		•	
S55452-D301-A100	SQM40.367A10	•		18 Nm / 65 s		6	•		6		7	•		•			
BPZ:SQM40.387A20	SQM40.387A20	•		18 Nm / 65 s		8	•		6		7	•			•		
BPZ:SQM40.387A23	SQM40.387A23	•		18 Nm / 65 s		8	•		6		7	•			•		•

**Type summary** (other types on request) (cont'd)

		Direct rota		or 90°			РСВ					Regi vers		-	rating tage	Pote	
Article no.	Туре	Counter- clockwise	Clockwise	Torque ') / running time ') for	Electronic version Diagram no.	Switch version Diagram no.	3-position	2-position	No. of switches	No. of relay	Shaft no.	EU	US / Canada	AC120V	AC230V	Double 90°	Double 135°
BPZ:SQM40.387R11	SQM40.387R11	•		18 Nm / 65 s		8	•		6		7		•	•		•	
BPZ:SQM41.141A21	SQM41.141A21		•	5 Nm / 15 s	4				3		1	•			•	•	
BPZ:SQM41.145A21	SQM41.145A21		•	5 Nm / 15 s	4				3		5	•			•	•	
BPZ:SQM41.161A20	SQM41.161A20		•	5 Nm / 15 s		6	•		6		1	•			•		
BPZ:SQM41.165R11	SQM41.165R11		•	5 Nm / 15 s		6	•		6		5		•	•		•	
BPZ:SQM41.185R11	SQM41.185R11		•	5 Nm / 15 s		8	•		6		5		•	•		•	
BPZ:SQM41.241A11	SQM41.241A11		•	10 Nm / 30 s	4				3		1	•		•		•	
BPZ:SQM41.241A21	SQM41.241A21		•	10 Nm / 30 s	4				3		1	•			•	•	
BPZ:SQM41.241R11	SQM41.241R11		•	10 Nm / 30 s	4				3		1		•	•		•	
BPZ:SQM41.244A21	SQM41.244A21		•	10 Nm / 30 s	4				3		4	•			•	•	
BPZ:SQM41.244R11	SQM41.244R11		•	10 Nm / 30 s	4				3		4		•	•		•	
BPZ:SQM41.245A11	SQM41.245A11		•	10 Nm / 30 s	4				3		5	•		•		•	
BPZ:SQM41.245A21	SQM41.245A21		•	10 Nm / 30 s	4				3		5	•			•	•	
BPZ:SQM41.245R11	SQM41.245R11		•	10 Nm / 30 s	4				3		5		•	•		•	

**Building Technologies Division** 

Type summary (other types on request) (cont'd)

		Direct rota		or 90°			РСВ					Regi vers		-	ating age	Pote me	ntio- eter
Article no.	Type	Counter- clockwise	Clockwise	Torque ¹) / running time ¹) for 90°	Electronic version Diagram no.	Switch version Diagram no.	3-position	2-position	No. of switches	No. of relay	Shaft no.	EU	US / Canada	AC120V	AC230V	Double 90°	Double 135°
BPZ:SQM41.254R11	SQM41.254R11		•	10 Nm / 30 s	5				4		4		•	•		•	
BPZ:SQM41.261A11	SQM41.261A11		•	10 Nm / 30 s		6	•		6		1	•		•		•	
BPZ:SQM41.261A21	SQM41.261A21		•	10 Nm / 30 s		6	•		6		1	•			•	•	
BPZ:SQM41.261R11	SQM41.261R11		•	10 Nm / 30 s		6	•		6		1		•	•		•	
BPZ:SQM41.264A21	SQM41.264A21		•	10 Nm / 30 s		6	•		6		4	•			•	•	
BPZ:SQM41.264R11	SQM41.264R11		•	10 Nm / 30 s		6	•		6		4		•	•		•	
BPZ:SQM41.265R11	SQM41.265R11		•	10 Nm / 30 s		6	•		6		5		•	•		•	
BPZ:SQM41.267A21	SQM41.267A21		•	10 Nm / 30 s		6	•		6		7	•			•	•	
BPZ:SQM41.271R10	SQM41.271R10		•	10 Nm / 30 s		7		•	5	1	1		•	•			
BPZ:SQM41.275A21	SQM41.275A21		•	10 Nm / 30 s		7		•	5	1	5	•			•	•	
BPZ:SQM41.275R10	SQM41.275R10		•	10 Nm / 30 s		7		•	5	1	5		•	•			
BPZ:SQM41.285R11	SQM41.285R11		•	10 Nm / 30 s		8	•		6		5		•	•			
BPZ:SQM41.357A23	SQM41.357A23		•	18 Nm / 65 s	5				4		7	•			•		•
BPZ:SQM41.357R11	SQM41.357R11		•	18 Nm / 65 s	5				4		7		•	•		•	
BPZ:SQM41.367A21	SQM41.367A21		•	18 Nm / 65 s		6	•		6		7	•			•	•	
BPZ:SQM41.387R11	SQM41.387R11		•	18 Nm / 65 s		8	•		6		7		•	•		•	

<sup>1)</sup> Specifications apply to ambient temperatures of 23 °C and a mains voltage of AC 120 V or AC 230 V and a mains frequency of 50 Hz. With a mains frequency of 60 Hz, the running times are approx. 17% shorter. Torques lower by the same rate.



#### Note

Not all types of actuators are available ex stock. Additional versions are available on request.

#### Drive shafts:

Type of drive shaft	Max. torque	Shaft no.
Ø 10 mm, woodruff key as per DIN 6888	10 Nm	1
☐ 9.5 mm, square shaft	15 Nm	4
Ø 10 mm D type shaft, compatible with SQM45	10 Nm	5
$\varnothing$ 14 mm with parallel key as per DIN 6885, compatible with SQM48	20 Nm	7

Accessories must be ordered as separate items:



Mounting plate **ASK33.1** 

For mounting the SQM40... / SQM41... onto the VKP... proportional controlling

See Mounting Instruction 74 319 0843 0 (M7646)



Mounting kit ASK33.4

For fitting SQM40... / SQM41... to the butterfly valve VKF41.xxC See Mounting Instruction 74 319 0916 0 (M7813 / 7814)



#### Front cover (on request)

For making the connections for the power supply lines

- For 1/2" NPT protective sleeve AGA45.11 - For metric cable gland AGA45.12



### Note!

Front covers AGA45.11 and AGA45.12 are only to be used as replacements. The corresponding AGA45... version is factory-prefitted onto the SQM40... / SQM41...

#### Connector sets (on request)



With screw terminals for replacement:

- For SQM4x.x1xxxx AGA45.1 AGA45.4 - For SQM4x.x4xxxx - For SQM4x.x2xxxx, SQM4x.x5xxxx AGA45.5 AGA45.6

- For SQM4x.x3xxxx, SQM4x.x6xxxx, SQM4x.x7xxxx, SQM4x.x8xxxx



#### Potentiometers (on request)

For retrofitting

- For SQM40... / SQM41...: Double potentiometer 2\*1000  $\Omega$ , 90° **ASZ22.32** - For SQM40...: Double potentiometer 2\*1000  $\Omega$ , 135° ASZ22.35 - For SQM41...: Double potentiometer 2\*1000  $\Omega$ , 135° ASZ22.34

Refer to Data Sheet N7921.



#### Note!

ASZ22... potentiometers are only intended for the retrofitting onto SQM40... / SQM41... types with the end number 0 (SQM4x.xxxx0).

For all SQM40... / SQM41... types with the end number 1 (SQM4x.xxxx1) or 3 (SQM4x.xxxx3), the potentiometers are already factory installed.

#### **Technical Data**

General unit data	Operating voltage							
	- SQM4x.xxxA1	AC 120 V -15%/+10%						
	- SQM4x.xxxA2	AC 230 V -15%/+10%						
	- SQM4x.xxxR1	AC 120 V -15%/+10%						
	Operating frequency	5060 Hz ±6%						
	Drive motor	Synchronous motor						
	Power consumption	10 VA						
	Operating angle	Between 0° and max. 90° or between 0°						
	Operating angle	and max. 135°, depending on the type						
	Mounting position	Optional						
	Degree of protection	IP66						
		IF 00						
	Safety class	May 6.2 AT (alou) to DIN EN 60427-2/5						
	External overload fuse	Max. 6.3 AT (slow) to DIN EN 60127-2/5						
	Internal overload fuse	2 AT (slow), depending on the type, non- exchangeable						
	Cable entry	2 x M16 without thread or 2 x ½" NPT thread, depending on the type						
	Wire cross-sectional area of the	0.52.5 mm <sup>2</sup>						
	connecting wires, including earth terminal (PE)							
	Direction of rotation	Facing the shaft end (mounting surface):						
	• SQM40	Counterclockwise (CCW)						
	• SQM41	Clockwise (CW)						
	Torque	2.5 Nm / 5 Nm / 10 Nm / 18 Nm,						
	- 1	depending on type 1)						
	Torque tolerance	-25%						
	4	Each valid at the tolerance limits of						
		temperature and operating voltage						
	Holding torque	50%						
		Of the torque for types with 5 Nm, 10 Nm, and 18 Nm torque						
		36%						
		Of the torque for types with 2.5 Nm torque						
	Running time	5 s, 15 s, 30 s and 65 s, depending on						
		type 1)						
	Running time tolerance	+10%						
	Pause time at change in direction of rotation, zero-current state	>100 ms						
	End and auxiliary switches							
	<ul> <li>Type</li> </ul>	To DIN 41636						
	<ul> <li>Switching voltage</li> </ul>	AC 24250 V						
	Switching capacity	See specifications in chapter <i>Connection diagrams</i>						
	Number of end switches	2						
	Number of auxiliary switches	Max. 4, depending on type						
	Drive shaft	Supplied as standard, non-exchangeable						
	Weight	Approx. 2 kg						
	Temperature of the mounting surface	Max. 60 °C						
	Rated surge voltage	Overvoltage category III in accordance with DIN EN 60730-1 chapter 20						
	Backlash between the actuator motor and	with bill Eld 00700-1 chapter 20						
	actuator shaft							
	- ex works	<1°						
		<1.2°						
	- after 250,000 cycles	×1.2						

Specifications apply to ambient temperatures of 23 °C and a mains voltage of AC 120 V or AC 230 V and a mains frequency of 50 Hz. With a mains frequency of 60 Hz, the running times are approx. 17% shorter. The torques lower by the same rate

15/29

	Lifetime	250,000 start cycles (close ⇒ open ⇒ close) under load with the rated torque in
		the entire rotation angle range. 2,000,000 control cycles under load with
		75% of rated torque in rotation angle range of 10°
Analog inputs	General	
	Linearity	<5% of the control range
	Control range	090° or 0135°, depending on type
	Voltage setpoint	DC 210 V
	X1-1 (U-IN), X1-2 (GND)	
	- Umin	DC 2 V
	- Umax	DC 10 V
	Input impedance	≥5 kΩ
	Current setpoint	DC 420 mA
	X1-3 (I-IN), X1-2 (GND)	
	- Imin	DC 4 mA
	- Imax	DC 20 mA
	Input impedance	≤500 Ω
	Impedance setpoint	0135 Ω
		0133 22
	X1-4, X1-5, X1-6 (GND)	10.5 0 50/
	- RNominal	135 Ω ±5%
or use in North	Cross-sectional area of the power supp	oly lines
America	SQM4x.x1xxxx / SQM4x.x4xxxx /	Class 1, min. AWG 16
	SQM4x.x5xxxx, (X2), (PE)	Suited for 105 °C
	SQM4x.x6xxxx / SQM4x.x7xxxx /	Max. 2.5 mm <sup>2</sup> or AWG 14
	SQM4x.x8xxxx, (X1)/(X2)/(X3), (PE)	
	SQM4x.x1xxxx / SQM4x.x2xxxx	Class 2, min. AWG 22
	SQM4x.x4xxxx / SQM4x.x5xxxx (X1)	Suited for 105 °C
		Max. 1 mm <sup>2</sup> or AWG 18
	NEMA classification	NEMA4 (in progress)
	Outdoor use	, , ,
	lack	Attention!
		Waterproof cable conduits and cable
		glands are required (e.g. type DWTT/7 or
		QCRV2/8)
Environmental conditions	Storage	DIN EN 60721-3-1
	Climatic conditions	Class 1K3
		Clase 1M2
	Mechanical conditions	Class 1M2
	Temperature range	-2060 °C
	Temperature range Humidity	-2060 °C <95% r.h.
	Temperature range Humidity Transport	-2060 °C <95% r.h. DIN EN 60721-3-2
	Temperature range Humidity Transport Climatic conditions	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3
	Temperature range Humidity Transport Climatic conditions Mechanical conditions	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2 -2060 °C
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2 -2060 °C <95% r.h.
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity Operation	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2 -2060 °C <95% r.h. DIN EN 60721-3-3
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2 -2060 °C <95% r.h.
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity Operation	-2060 °C <95% r.h. DIN EN 60721-3-2 Class 2K3 Class 2M2 -2060 °C <95% r.h. DIN EN 60721-3-3
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity Operation Climatic conditions	-2060 °C <95% r.h.  DIN EN 60721-3-2  Class 2K3  Class 2M2 -2060 °C <95% r.h.  DIN EN 60721-3-3  Class 3K5
	Temperature range Humidity Transport Climatic conditions Mechanical conditions Temperature range Humidity Operation Climatic conditions Mechanical conditions	-2060 °C <95% r.h.  DIN EN 60721-3-2  Class 2K3  Class 2M2 -2060 °C <95% r.h.  DIN EN 60721-3-3  Class 3K5  Class 3M4




#### Notice!

Condensation, formation of ice, and ingress of water are not permitted. If this is not observed, there is a risk of loss of safety functions and a risk of electric shock.

## Conductive plastic potentiometer

Resistance	2*1000 $\Omega$ double potentiometer with
	separated resistance tracks
Operating voltage	DC 10 V
Permissible hysteresis	0.3% of 90° or of 135°, depending on type
Total resistance tolerance	±20%
Effective angular rotation	90° or 135°, depending on type
Terminal strip	Triple-pole
For cross-sectional areas of	0.51 mm²
Wiper current rating	Max. 100 μA
Transfer resistance of wiper contact	Max. Rü ≤ 100 Ω
Linearity (referred to Rges = 1000 $\Omega$ )	±1%
Smoothness (alpha = 10°) / microlinearity	<0.5%
Life cycle	Approx. 2 million positioning cycles
Temperature coefficient	0.4 Ω/K

Conductive plastic potentiometer connection diagram



Potentiometer drawn in start position (as supplied).

Terminal markings:

a = high end of potentiometer

b = potentiometer wiper

c = low end of potentiometer

Apply operating voltage only on terminals **«a»** and **«c»**. Conductive plastic potentiometers can be destroyed if operating voltage is applied incorrectly between **«a**  $\rightarrow$  **b»** or **«b**  $\rightarrow$  **c»**.

The polarity of the potentiometer end pickups  $(a \rightarrow c)$  must be observed in order to achieve the correct signal direction to the potentiometer wiper (b).

If the potentiometer specified for  $90^{\circ}$  is operated outside of the effective range of angular rotation of  $90^{\circ}$ , no valid signal will be present at the wiper contact (interrupted circuit). This can happen if the switch position of the switching cam I for high-fire is configured for over  $90^{\circ}$ .

The 90° version ASZ22.32 can be used for both directions of rotation, SQM40... (counterclockwise) and SQM41... (clockwise).

The 135° versions ASZ22.34 and ASZ22.35 are each intended for a particular direction of rotation.

The direction of rotation of the potentiometer must correspond with the direction of rotation of the actuator as follows:


- ASZ22.34 can only be used with SQM41... (clockwise)
- ASZ22.35 can only be used with SQM40... (counterclockwise)

#### SQM4x.x1xxxx

Electronic version



For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Mains	voltage terminals		Dimensioning
X1-1	210 V	Input	max. DC 10 V to X1-5
X1-2	420 mA	Input	max. 20 mA to X1-5
X1-3	$0135\Omega1$	Input	
X1-4	$0135\Omega2$	Input	
X1-5	0135 Ω 3 (GND)	Input	
X2-1	Open (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-2	Move to low-fire (V)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-3	Low-fire position reached (V)	Output	AC 120 V / AC 230 V max. 10 mA, cosφ >0.9
X2-4	Close / ignition (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Controller release	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-6	Neutral	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-7	Open position reached (I)	Output	AC 120 V / AC 230 V max. 10 mA, cosφ >0.9
Mains	voltage terminals		Dimensioning
X2-1	Open (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-2	Move to low-fire (V)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-3	Low-fire position reached (V)	Output	AC 120 V / AC 230 V max. 10 mA, cosφ >0.9
X2-4	Close / ignition (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Controller release	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-6	Neutral	Input	AC 120 V / AC 230 V

Output

Open position reached (I)

It is not permitted to connect additional external loads, such as signal lamps.

Range adjustment

See SQM4x.x4xxxx in this chapter.

18/29

max. 60 mA / 30 mA

AC 120 V / AC 230 V

max. 10 mA,  $\cos \varphi > 0.9$ 

<sup>\*</sup> Only the control lines to the burner controls or to the control unit may be connected at the marked terminals.


#### SQM4x.x2xxxx

Electronic version, only for types with 5 seconds running time



#### Note

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Low-v	oltage terminals	Dimensioning	
X1-1	420 mA	Input	max. 20 mA to X1-2
X1-2	GND	Input	
Mains	voltage terminals		Dimensioning
X2-1	Open position reached (I)	Output	AC 120 V / AC 230 V max. 10 mA, $\cos \phi$ >0.9
X2-2	Open, high-fire (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-3	Auxiliary switch AUX (IV) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-4	Auxiliary switch AUX (IV)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Auxiliary switch AUX (IV) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-6	Low-fire position / ignition load position reached (V / VI)	Output	AC 120 V / AC 230 V max. 10 mA, $cos\phi > 0.9$
X2-7	Close / ignition (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9*
X2-8	Neutral	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-9	Controller release	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA

<sup>\*</sup> Only the control lines to the burner controls or to the control unit may be connected at the marked terminals.

It is not permitted to connect additional external loads, such as signal lamps.

Range adjustment


#### SQM4x.x3xxxx

2-position version with 2 end switches and 2 auxiliary switches, 3 relays



#### Notel

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Mains voltage terminals		Dimensioning	
X1-1	Free		
X1-2	Controller, open	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-3	Controller release	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-4	Auxiliary switch AUX (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X1-5	Neutral	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-6	Auxiliary switch AUX (VI) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X2-1	Fan supply voltage	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-2	Mains voltage, close	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-3	Low-fire controller	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-4	Fan motor	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Free		
X3-1	Auxiliary switch AUX (VI) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-2	Open (I) / close (II), changeover relay K-C	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X3-3	Operation, changeover relay K-B	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9



#### Notice!

\*\* When connecting a fuel valve: Max. 0.3 A, cosφ >0.8 inductive.

Range adjustment


#### SQM4x.x4xxxx

#### Electronic version



#### Note!

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Low-v	oltage terminals		Dimensioning
X1-1	210 V	Input	max. DC 10 V to X1-2
X1-2	GND	Input	
X1-3	420 mA	Input	Max. 20 mA to X1-2
X1-4	$0135\Omega1$	Input	
X1-5	$0135\Omega2$	Input	
X1-6	0135 Ω 3 (GND)	Input	
Maina	voltage terminals		Dimensioning

Mains	voltage terminals	Dimensioning	
X2-1	Opening (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-2	Move to low-fire (V)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-3	Position reached	Output	AC 120 V / AC 230 V max. 10 mA, $\cos \phi$ >0.9
X2-4	Closing/ignition (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Controller release	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-6	Neutral	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA

<sup>\*</sup> Only the control lines to the burner controls or to the control unit may be connected at the marked terminals.

It is not permitted to connect additional external loads, such as signal lamps.

#### Range adjustment


Adjust the range of the analog signal to match the switch positions (min. and max. position):

- 1. Set cam I to the required high-fire position (e.g. 85°; position is indicated on the scale next to the cam).
- 2. Set cam V to the required low-fire position (e.g. 20°).
- 3. Preset the signal at the analog input according to the required high-fire position (e.g. 20 mA).
- 4. Turn the potentiometer for maximum angular rotation
  - a) clockwise, if the actuator has not yet reached its maximum angular rotation, or
  - b) counterclockwise until the actuator starts
- 5. Preset the signal at the analog input according to the low-fire position (e.g. 4 mA).
- 6. Turn the potentiometer for minimum angular rotation
  - a) counterclockwise, if the actuator has not yet reached its minimum angular rotation, or
  - b) clockwise until the actuator starts

Modulation always takes place between high- and low-fire.


Also, it is possible to define a closed position or a separate ignition position by setting cam VI (independent of cam V, e.g. for defining a position higher than the low-fire position).

21/29



#### Note!


When starting up, the direction of rotation of the potentiometer setting must be observed:





#### Note

The working range of the potentiometer setting, shown as an example for the current input 4...20 mA.




#### SQM4x.x5xxxx

Electronic version



#### Note

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Low-v	oltage terminals	Dimensioning	
X1-1	420 mA	Input	max. 20 mA to X1-2
X1-2	GND	Input	
Mains	voltage terminals		Dimensioning
X2-1	Open position reached (I)	Output	AC 120 V / AC 230 V max. 10 mA, $\cos \phi$ >0.9
X2-2	Open / high-fire (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-3	Auxiliary switch AUX (IV) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-4	Auxiliary switch AUX (IV)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Auxiliary switch AUX (IV) / NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-6	Low-fire position / ignition load position reached (V, VI)	Output	AC 120 V / AC 230 V max. 10 mA, $cos\phi > 0.9$
X2-7	Close / ignition (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 *
X2-8	Neutral	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA
X2-9	Controller release	Input	AC 120 V / AC 230 V max. 60 mA / 30 mA

<sup>\*</sup> Only the control lines to the burner controls or to the control unit may be connected at the marked terminals.

It is not permitted to connect additional external loads, such as signal lamps

Range adjustment


#### SQM4x.x6xxxx

3-position version with 2 end switches and 4 auxiliary switches



#### Note!

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Mains	voltage terminals	Dimensioning	
X1-1	Move to ignition position (III)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-2	Auxiliary switch AUX (IV) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-3	Auxiliary switch AUX (IV)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-4	Neutral		AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-5	Closing (II)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-6	Opening (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-1	Auxiliary switch AUX (V)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-2	Auxiliary switch AUX (V) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-3	Open position reached (I)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X2-4	Close position reached (II)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X2-5	Ignition position reached (III)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X3-1	Auxiliary switch AUX (VI) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-2	Auxiliary switch AUX (VI) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-3	Auxiliary switch AUX (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **



#### Notice!

\*\* When connecting a fuel valve: Max. 0.3 A, cosφ >0.8 inductive.

Range adjustment


#### SQM4x.x7xxxx

2-position version with 2 end switches and 3 auxiliary switches, 1 relay



#### Note!

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Mains	Mains voltage terminals		Dimensioning
X1-1	Move to ignition position (III)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-2	Auxiliary switch AUX (IV) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-3	Auxiliary switch AUX (IV)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-4	Neutral		AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-5	Closing (II)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-6	Opening (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-1	Mains voltage	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-2	Open / close relay	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-3	Open position reached (I)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X2-4	Close position reached (II)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X2-5	Ignition position reached (III)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X3-1	Auxiliary switch AUX (VI) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-2	Auxiliary switch AUX (VI) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-3	Auxiliary switch AUX (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **



#### Notice!

\*\* When connecting a fuel valve: Max. 0.3 A, cosφ >0.8 inductive.

Range adjustment


#### SQM4x.x8xxxx

3 position version with 2 end switches and 4 auxiliary switches



#### Note!

For the sake of clarity, the plug-in contacts do not appear in sequential order in the circuit diagram. Consecutive numbers are printed on the unit, however, e.g. 1...7.



Mains	voltage terminals		Dimensioning
X1-1	Move to position (III)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-2	Auxiliary switch AUX (IV) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-3	Auxiliary switch AUX (IV)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-4	Neutral	Input	AC 120 V / AC 230 V max. 1 A, $cos_{\phi} > 0.9$ inductive
X1-5	Closing (II)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X1-6	Opening (I)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-1	Auxiliary switch AUX (V)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-2	Auxiliary switch AUX (V) NO contact	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-3	Position reached (I / II / III)	Output	AC 120 V / AC 230 V max. 0.3 A, cosφ >0.8
X2-4	Auxiliary switch AUX (IV) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X2-5	Auxiliary switch AUX (V) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9
X3-1	Auxiliary switch AUX (VI) NO contact	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-2	Auxiliary switch AUX (VI) NC opener	Output	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **
X3-3	Auxiliary switch AUX (VI)	Input	AC 120 V / AC 230 V max. 1 A, cosφ >0.9 **



#### Notice!


\*\* When connecting a fuel valve: Max. 0.3 A, cosφ >0.8 inductive.

Range adjustment

Position indication SQM40...

External angle scale
Marking in slot shape

Position indication SQM41...
Internal angle scale
Arrow marking





#### Note!

The setting of the switch positions must be checked before startup.

SQM4x.x1xxxx SQM4x.x4xxxx

Electronic version				
Cam	Color	Position	Preadjustment	
Cam I	Red	High-fire	90°	
Cam II	Blue	Not used		
Cam III	Orange	Not used		
Cam IV	Yellow	Not used		
Cam V	Black	Low-fire	15°	
Cam VI	Green	OFF / ignition	0°	

SQM4x.x3xxxx

2 position version				
Cam	Color	Position	Preadjustment	
Cam I	Red	High-fire	90°	
Cam II	Blue	OFF / low-fire	0°	
Cam III	Orange	Ignition position	15°	
Cam IV	Yellow	Not used		
Cam V	Black	Not used		
Cam VI	Green	Auxiliary switch	30°	

SQM4x.x2xxxx SQM4x.x5xxxx

Electronic version				
Cam	Color	Position	Preadjustment	
Cam I	Red	High-fire	90°	
Cam II	Blue	Not used		
Cam III	Orange	Not used		
Cam IV	Yellow	Auxiliary switch	30°	
Cam V	Black	Low-fire	30°	
Cam VI	Green	OFF / ignition	0°	

SQM4x.x6xxxx SQM4x.x8xxxx


3 position version				
Cam	Color	Position	Preadjustment	
Cam I	Red	High-fire	90°	
Cam II	Blue	OFF / low-fire	0°	
Cam III	Orange	Ignition position	15°	
Cam IV	Yellow	Auxiliary switch	30°	
Cam V	Black	Auxiliary switch	30°	
Cam VI	Green	Auxiliary switch	30°	

SQM4x.x7xxxx

3 position version			
Cam	Color	Position	Preadjustment
Cam I	Red	High-fire	90°
Cam II	Blue	OFF / low-fire	0°
Cam III	Orange	Ignition position	15°
Cam IV	Yellow	Auxiliary switch	30°
Cam V	Black	Not used	
Cam VI	Green	Auxiliary switch	30°

#### Dimensions in mm

#### SQM40.../SQM41...



© 2016 Siemens AG Building Technologies Division, Berliner Ring 23, D-76437 Rastatt Subject to change!